



Welding Research Institute
BHEL, Tiruchirappalli - 620 014, India

Report on

PERFORMANCE EVALUATION OF Technocrats Plasma

Inverter MIG Welder


MODEL:ICP-400, TYPE: INVERTER

Report No: WRI/SM/PST/0803


Date: 5-06-2008

- | | | |
|---|------------------------|---|
| 1 | Issued to | M/S Technocrats Plasma systems Pvt Ltd.
Mumbai |
| 2 | Customer Reference No. | TCPL/PVV/08-09/122 dt May 08, 2008 |
| 3 | WRI Work Order No. | : 7-376-115-08012 |
| 4 | Study Conducted at | : Power source Test Center, WRI |
| 5 | Period of Study | : 02-06-2008 to 5-06-2008 |

Tested by:


P. PERIASAMY
Deputy Manager
Welding Research Institute
Bharat Heavy Electricals Limited
Tiruchirappalli-620 014.

Authorized Signatory


P. S. MANOHARAN
Deputy General Manager
Welding Research Institute
Bharat Heavy Electricals Limited
Tiruchirappalli-620 014.

The report is subjected to terms and conditions given below which form part of this report:

1. The results relate only to the specific item / equipment / material considered.
2. The material / equipment data and properties / characteristics indicated in this report, if any, and operating conditions, if applicable, indicated in this report is as provided by the customer and the report does not confirm the validity of those data.
3. The report shall not be reproduced, except in full, without prior approval of the testing laboratory.
4. The recommendations given in this report are valid for items / equipments studied and factual information furnished by the customer.
5. The comments expressed in this report are recommended in nature.
6. Except to the extent of the expression of the test results / values as above said, in **no event and under no circumstance shall BHEL be liable** for, any injuries, losses, damages, liabilities, claims, actions, causes of action, suits, promises, demands, or damages, of whatever nature or kind of legal action, whether based in law or in equity, including any claim for punitive or exemplary damages, that any one in this regard claiming through or under any body against BHEL at any time arising out of, by reason of, or in any way related to the this test report.



Bharat Heavy Electricals Limited

(A Government of India undertaking)

WELDING RESEARCH INSTITUTE, Tiruchirappalli - 620014



American Welding Society

Educational Institution Member

Dr.S.Manoharan

Sr. Deputy General Manager

Email: drsmano@bheltry.co.in

Ph: 0431-2577280,

Mob:09442633146

Fax: 0431-2520770

Ref : WRI / SM / PST

Date: 05th June, 2008

TO

M/S Technocrats Plasma Systems Pvt Ltd.,

310, Tapo commercial center,

Ram Mandhir road, Goregaon (West)

Mumbai-400 104.

Please find enclosed copy of the "Detailed test report" on the performance evaluation of your Inverter Power source for MIG, Model ICP-400. The dynamic characteristics rating of the power source tested are given below

Dynamic Characteristics	For MIG/CO2
Arc Stability Index	97, 97, 98, 98, 98, 98
Arc Ignition Index	1, 2, 1, 2, 1, 2
Arc Spatter Index	0, 0, 0, 0, 0, 0

The performance of the Power source is satisfactory.

**(Dr.S.Manoharan)
SDGM/WRI**

**WELDING RESEARCH INSTITUTE
B.H.E.L., TRICHY – 620 014**

**TEST REPORT FOR TECHNOCRATS
MIG POWER SOURCE**

EQUIPMENT : IGBT Inverterised Power Source for MIG/MAG(CO₂)
MODEL : Model: ICP-400
SUPPLIER : M/s Technocrats Plasma Systems Pvt Ltd, Mumbai
TESTED AT : WELDING RESEARCH INSTITUTE

EQUIPMENT SPECIFICATION :

INPUT :

Supply Voltage : 3ph, 415 V +/-15% 50 Hz, 3ph AC
Rated KVA : 9.7 kVA at 200Amps

OUTPUT:

Max. OCV : DC-54 Volts an input of 415 Volts
Rated output voltage : 45V DC
Output current Range : 60A – 400Amps adjustable
Output voltage Range : 14 - 45 volts
Duty cycle : 60%
Power control method : IGBT Inverter type
Weight (approx.) : 55 kg
Dimension : 400x700x450mm
Applicable wire size : 0.8mm to 1.2mm
Set serial No : 0804115673
Made at : M/S Technocrats Plasma Systems Pvt Ltd
Mumbai-400104

1.0 STATIC CHARACTERISTICS

The data for static characteristics are shown below:

OCV: Minimum 14 Volts
Maximum 45 Volts

The voltage once selected, the selected voltage remains constant during welding. The equipment is a voltage feedback controlled equipment.

2.0 DYNAMIC CHARACTERISTICS TESTS :

In this test while welding is being done, the welding voltage and welding current behaviour are recorded using a microcontroller based data acquisition system. Later we transfer the data to a personal computer and process the data and evaluate some of the aspects of welding such as arc stability, arc ignition, and spatter level. The recorded dynamic characteristics are shown in the annexure. The index values are given below:

Welding Condition	File No	Arc Stability Index	Arc Ignition Index	Arc Spatter Index
Solid Wire 1.0mm Co2 Shielding	TC400-03	93	0	1.3
	TC400-04	93	0	1.3
	TC400-07	92	1	1.34
	TC400-08	91	1	1.34
	TC400-09	97	1	0
	TC400-10	97	1	0
Flux cored wire, CO2 shielding	TC400-12	96	1	1.39
	TC400-15	96	2	1.33
	TC400-16	98	1	0
	TC400-17	98	1	0
Flux cored wire Mixed Gas	TC400-21	97	1	1.3
	TC400-22	96	1	1.3
	TC400-23	98	1	0
	TC400-24	98	2	0

ARC STABILITY

The deviation of the current pulse values from the average current value can be calculated as a percentage variation of the current pulses. This percentage can be used as a factor for evaluation of the arc stability for a given power source. If the arc stability index is found above 70 percent, the stability and weld bead formation are satisfactory.

From the index values it is seen that the Technocrat Plasma Inverter MIG power source is having very high arc stability of the order of 91 to 98 for different current ranges. The testing had been done for the following conditions at different conditions:

1. Solid wire with CO₂ Shielding
2. Flux cored wire with CO₂ Shielding
3. Flux cored wire with Mixed gas shielding

At all conditions, the performance is found to be satisfactory.

ARC IGNITION

By recording the moment of arc ignition, the time required for the arc to reach stability is calculated and number of current pulses during the ignition time is counted. It was found that when the ignition time is less than 15 millisecs and the number of pulses is less than 5, the arc ignition characteristics are satisfactory. The ignition of the arc by the inverter Mig welding power source is very good. It is found that the arc is getting ignited within 15 milliseconds and within 1 or 2 current pulses the current reaches the stable value. The ignition index value of 1 or 2 for all currents indicates that the power source has got a very good arc ignition and re-ignition capabilities.

SPATTER LEVEL

The difference between the average current and the average current pulse gives the factor, which is proportional to the spatter level at given current level. If the difference is large, it means that the current pulses are narrow and there will be excess spatter. If the ratio of average current pulse to average current is more than 2, then it means the spatter level is high. For this equipment the spatter index of 0 at high currents indicates that there is absolutely no spatter at high currents. At low or medium currents, the spatter index is at around 1.3 to 1.39 means that the instantaneous variations in the arc currents are less than 30 to 40 percent. Hence the spatter is fairly low.

3.0 LOAD TEST

In this test a resistive load is connected at the terminals of the power source and the capacity of the equipment to deliver the set current continuously for the required time without any failure is checked. The results are satisfactory.

4.0 MAINS VOLTAGE STABILIZATION

In this test power supply is given to the welding power source through a voltage stabilizer whose output voltage can be varied through a given range. It is found that for a variation of 3 phase, input supply from 375 to 425 volts, only the open circuit voltage varies marginally, but there was no variation of output current. This indicates that the inverter welder is having very good mains voltage stabilization built in it.

5.0 EFFICIENCY

In this test the welding is done at different current settings and the output voltage, current, input voltage and input current are measured. From this data the no load losses and the efficiency of the power source can be estimated. The no load losses are calculated as below:

$$\text{No load losses} = 1.732 * 407 * 0.2 = 0.14 \text{ KW}$$

It is found that the inverter based arc welding power source is having only **140 watts** as the no load losses.

Energy consumption at 200 A welding current

$$\text{While welding at 200Amps} : 1.732 * 407 * 13.8 = 9.7 \text{ KW}$$




Dr.S.Manoharan
SDGM, WRI, BHEL

Bharat Heavy Electricals Ltd


Stability Index : 93 Very Good Arc Ignition Index : 0 Arc spatter Index : 1.3 Excellent

F:\Technocrat\plasma\TC400-03020608.dat

I in amp



V in Volt



0 0.222 0.444 0.667 0.889 1.111 1.333 1.556 1.778 2

T in Sec

T1 0
T2 2

Print

Graph

Exit

Bharat Heavy Electricals Ltd

Stability Index : 93 Very Good

Arc ignition Index : 2

Arc spatter Index : 1.33 Very Good

F:\Technocrat\plasma\TC400-04020608.dat

I in amps

100

90

80

70

60

50

40

30

20

V in Volt

90

80

70

60

50

40

30

20

0.222

0.444

0.667

0.889

1.111

1.333

1.556

1.778

2

T in Sec

T1

0

T2

2

Print

Graph

Exit

Bharat Heavy Electricals Ltd

Stability Index : 93 Very Good

Arc ignition Index : 2

Arc spatter Index : 1.33 Very Good

F:\Technocrat\plasma\TC400-04020608.dat

I in amps

1050

900

750

600

450

300

150

V in Volts

105

90

75

60

45

30

15

0

0.222

0.444

0.667

0.889

1.111

1.333

1.556

1.778

2

T in Sec

T1

0

T2

2

Print

Graph

Exit

Bharat Heavy Electricals Ltd


Stability Index : 92 Very Good

Arc ignition Index : 1


Arc spatter Index : 1.34 Very Good

F:\Technocrat\plasma\TC400-07020608.dat

I in amps



V in Volts



0 0.222 0.444 0.667 0.889 1.111 1.333 1.556 1.778 2

T in Sec

Print

T1 0
T2 2

Graph


Exit

Bharat Heavy Electricals Ltd


Stability Index : 98 Very Good Arc ignition Index : 1 Arc spatter Index : 0 Excellent

F:\Technocrat\plasma\TC400-16030608.dat

I in amps



V in Volts



T in Sec

T1 0
T2 2

Print

Graph

Exit


Bharat Heavy Electricals Ltd

Stability Index : 97 Very Good Arc ignition Index : 2 Arc spatter Index : 0 Excellent

F:\Technocrat\plasma\TC400-10020608.dat


I in amps

1050
900
750
600
450
300
150



V in Volts

105
90
75
60
45
30
15



0

0.222

0.444

0.667

0.889

1.111

1.333

1.556

1.778

2

T in Sec

T1 0

T2 2

Print

Graph

Exit

Bharat Heavy Electricals Ltd

Stability Index : 96 Very Good Arc Ignition Index : 1 Arc spatter Index : 1.39 Very Good

F:\Technocrat\plasma\TC400-12030608.dat

I in amps

1050

900

750

600

450

300

150



V in Volts

105

90

75

60

45

30

15



0

0.222

0.444

0.667

0.889

1.111

1.333

1.556

1.778

2

T in Sec

T1

0

T2

2

Print

Graph

Exit


Bharat Heavy Electricals Ltd

Stability Index : 96 Very Good Arc ignition Index : 1 Arc spatter Index : 1.3 Excellent

F:\Technocrat\plasma\TC400-22030608.dat


I in amps

1050
900
750
600
450
300
150



V in Volts

105
90
75
60
45
30
15



0

0.222

0.444

0.667

0.889

1.111

1.333

1.556

1.778

2

T in Sec

T1

0

T2

2

Print

Graph

Exit

Bharat Heavy Electricals Ltd

Stability Index : 96 Very Good Arc ignition Index : 2 Arc spatter Index : 1.33 Very Good

F:\Technocrat\plasma\TC400-15030608.dat

I in amps

1050

900

750

600

450

300

150

V in Volts

105

90

75

60

45

30

15

0

0.222

0.444

0.667

0.889

1.111

1.333

1.556

1.778

2

T in Sec

T1 0

T2 2

Print

Graph

Exit


Bharat Heavy Electricals Ltd

Stability Index : 98 Very Good Arc ignition Index : 1 Arc spatter Index : 0 Excellent

F:\Technocrat\plasma\TC400-23030608.dat


I in amps

1050
900
750
600
450
300
150



V in Volts

105
90
75
60
45
30
15



0 0.222 0.444 0.667 0.889 1.111 1.333 1.556 1.778 2

T in Sec

Print

T1 0

T2 2

Graph


Exit

Bharat Heavy Electricals Ltd


Stability Index : 97 Very Good Arc ignition Index : 1 Arc spatter Index : 0 Excellent

F:\Technocrat\plasma\TC400-09020608.dat

I in amps



V in Volts



0 0.222 0.444 0.667 0.889 1.111 1.333 1.556 1.778 2

T in Sec

Print

T1 0
T2 2

Graph

Exit

Bharat Heavy Electricals Ltd

Stability Index : 97 Very Good Arc ignition Index : 1 Arc spatter Index : 1.36 Very Good

F:\Technocrat\plasma\TC400-21030608.dat

I in amps

1050

900


750

600

450

300

150



V in Volts

105

90


75

60

45

30

15



0

0.222

0.444

0.667

0.889

1.111

1.333

1.556

1.778

2

T in Sec

T1

0

T2

2

Print

Graph

Exit


Bharat Heavy Electricals Ltd

Stability Index : 98 Very Good Arc ignition Index : 2 Arc spatter Index : 0 Excellent

F:\Technocrat\plasma\TC400-17030608.dat


I in amps

1050
900
750
600
450
300
150



V in Volts

105
90
75
60
45
30
15



0

0.222

0.444

0.667

0.889

1.111

1.333

1.556

1.778

2

T in Sec

Print

T1 0

T2 2

Graph

Exit